



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.effectis.com

DECLARATION OF TEST RESULTS

No: EEA – 2200 – 0036

The fire resistance tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 02.08.2022 in accordance with the test standard:

EN 1634-1:2014+A1:2018

“Dekoratif Teknik Oda Kapısı”

SINGLE LEAF STEEL DOOR

FIRE RESISTANCE CLASSIFICATION	
Direction: Opening away from the fire	E60

Placed on the market by: BAKIRCILAR ÇELİK KAPI ALÜMİNYUM MOBİLYA MADENCİLİK
MERMER İNŞAAT TİCARET VE SANAYİ LİMİTED ŞİRKETİ
Odabaşı Mahallesi 9681 Sk. No:11
Kepez, Antalya/TÜRKİYE

Manufactured by: BAKIRCILAR ÇELİK KAPI ALÜMİNYUM MOBİLYA MADENCİLİK
MERMER İNŞAAT TİCARET VE SANAYİ LİMİTED ŞİRKETİ
Odabaşı Mahallesi 9681 Sk. No:11
Kepez, Antalya/TÜRKİYE

e-signed
Ali BAYRAKTAR
Laboratory Manager
07.02.2025

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: EEA-22-089.

